



READING PUBLIC SCHOOLS

Harry K. Harutunian, Ph.D.
Superintendent

62 Oakland Road
Reading, Massachusetts 01867

Tel. 781-942-5492 • Fax 781-942-5436

Domenic Cacciapuoti
Director of Facilities

TO: Dr. Harutunian
FROM: Domenic Cacciapuoti *D.C.*
DATE: January 30, 2003

The malfunction of the valves in the English and Math Department was due to the deterioration of the valves and the hard water.

If you have any further questions or concerns, please feel free to contact me.

3/31/03